



Missouri Department of Health and Senior Services  
 Bureau of Ambulatory Care  
 Missouri Radiation Control Program  
 P.O. Box 570, 920 Wildwood, Jefferson City, MO 65102-0570  
 Phone: 573-751-1588 FAX: 573-751-6648  
 Email: [BAC@health.mo.gov](mailto:BAC@health.mo.gov)



## Initial Ambulatory Surgery Center (ASC) Licensure Survey Preparedness Checklist (09/18/19)

**Facility Name:**

**Project ID number:**

For an initial ASC license to be issued, the facility must be completely ready to offer patient care, and be able to demonstrate full compliance with all regulations. This compliance must be verified by an onsite licensure survey by the Bureau of Ambulatory Care (BAC) prior to the facility being legally permitted to provide any patient services as an ASC. The BAC office must be notified and updated regularly with realistic completion dates of any construction prior to arranging the initial survey. The facility must be fully prepared to demonstrate compliance with all licensure rules as described at the following link:

<http://sos.mo.gov/adrules/csr/current/19csr/19c30-30.pdf>

**For all items below, before onsite survey can be scheduled, facility should indicate readiness by noting the date each item is complete, as well as the initials of the facility staff member responsible for assuring compliance.**

\_\_\_\_/\_\_\_\_ The facility has completed all reviews required by the DHSS Engineering Consultation Unit (ECU) to determine compliance with construction standards as described at 19 CSR 30-30.040, including a final plan approval and at typically two site visits by ECU staff. ECU phone number is 573-526-8610. [ECU@health.mo.gov](mailto:ECU@health.mo.gov)

Date of ECU onsite visit(s) \_\_\_\_/\_\_\_\_

◇ \_\_\_\_/\_\_\_\_ The facility has completed and mailed to BAC its licensure application to be an ASC, including submission of a \$200 licensure fee:

<http://health.mo.gov/safety/asc/pdf/AmbulatorySurgicalCenterLicenseApplication.pdf>

Send the application to [BAC@health.mo.gov](mailto:BAC@health.mo.gov).

◇ \_\_\_\_/\_\_\_\_ The facility can apply for a Bureau of Narcotics and Dangerous Drugs (BNDD) registration for the facility and that application will be active for 60 days. One issued not for the individual physicians but for the facility itself, as well as proper registration with the DEA. **Be aware that processing of these registrations can take several weeks, so this must be done early, but only after the ASC license has been issued.** BNDD can be reached at 573-751-6321, or online at <http://health.mo.gov/safety/bnnd>

◇ \_\_\_\_/\_\_\_\_ For any laboratory tests performed, the facility has obtained a Clinical Laboratory Improvement Act (CLIA) certificate identifying the physician in charge of laboratory services. **Processing of this certificate can take several weeks.** The CLIA program can be contacted at 573-751-6318 or [BOH@health.mo.gov](mailto:BOH@health.mo.gov)

[www.health.mo.gov](http://www.health.mo.gov)

Healthy Missourians for life.

The Missouri Department of Health and Senior Services will be the leader in promoting, protecting and partnering for health.

AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER: Services provided on a nondiscriminatory basis.

- ◇ \_\_\_\_/\_\_\_\_ If radiology services are to be provided, the facility has documentation *in writing* showing that appropriate policies been developed and training provided for safety, operation and monitoring of the radiology devices. X-ray equipment must be registered with the Missouri Radiation Control Program which can be reached at 573-751-6083, or via email at [MRCP@health.mo.gov](mailto:MRCP@health.mo.gov) . For additional information see <http://health.mo.gov/safety/radprotection/>
  - MRCP Registration# Assigned \_\_\_\_\_
  - Qualified Expert (QE) in radiation safety must have evaluated radiation shielding and performed a machine performance inspection. QE consultation should be done well before facility opens, as this can take several weeks to schedule. QE name or ID \_\_\_\_\_ and Date of QE Inspection \_\_\_\_\_
  
- ◇ \_\_\_\_/\_\_\_\_ The facility has obtained and has appropriately stocked all routine (non-controlled substances) and emergency medications, and all necessary supplies.
  
- ◇ \_\_\_\_/\_\_\_\_ All needed equipment and furnishings have been delivered, installed, and checked/inspected as ready for use in patient care, including documentation *in writing* that all clinical equipment, including sterilizers, has been checked/inspected as ready for use, including:
  - Sterilizers
  - Emergency/Crash carts
  - All equipment and instruments used routinely in procedures
  
- ◇ \_\_\_\_/\_\_\_\_ Complete and comprehensive bylaws and rules have been developed, **specific to your facility**, and approved *in writing* for:
  - Medical Staff (including new appointments recommended by Medical staff and approved by the Governing Body for both membership and privileges) and
  - Governing Body
  
- ◇ \_\_\_\_/\_\_\_\_ Complete and comprehensive policies, **specific to your facility** (not adopted from another facility) *in writing* have been approved by the Governing Body for:
  - Nursing services
  - Medical Records (including what elements need to be included)
  - Infection Control
  - Cleaning & Housekeeping
  - Medication administration
  - Emergency preparedness
  - Surgical procedures
  - Anesthesia
  - Emergency transfer agreement/protocol
  - Laboratory services (including which tissues are to be sent to a pathologist)
  - QAPI (Quality Assurance & Performance Improvement) Program, including proper identification of problems, collection of necessary data, routine data analysis and assessment of progress.
  - Overall facility operations not included above.

- ◇ \_\_\_\_/\_\_\_\_ Facility has documentation available *in writing* that ALL staff have been oriented and had the necessary in-service education related to routine facility operations and locations of both emergency and routine equipment. Staff is able to demonstrate familiarity with policies and procedures for their position.
  
- ◇ \_\_\_\_/\_\_\_\_ Facility has complete personnel files for all nursing and support staff, and all credentialing files for medical staff. All job descriptions have been developed *in writing* and included in each packet. Both criminal background checks and Missouri Employee Disqualification List (EDL) checks have been completed for each employee. For additional information on these requirements see <http://health.mo.gov/safety/edl/index.php> and <http://www.moga.mo.gov/mostatutes/stathtml/19200024951.html> Note: your facility can meet both parts of this requirement by utilizing the DHSS Family Care Safety Registry. You can reach FCSR by phone at 573-526-1974. For additional information including online access, please see <http://www.health.mo.gov/safety/fcsr/about.php>
  
- ◇ \_\_\_\_/\_\_\_\_ Facility has an established staffing schedule *in writing* to demonstrate that the center will be fully staffed when open.
  
- ◇ \_\_\_\_/\_\_\_\_ **Fire, Life Safety, and Mechanical Systems:** Facility has documentation *in writing* for each of the following:
  - Fire and smoke ratings for carpet, curtains, flooring and interior finish.
  - Test and balance for the heating and air conditioning to ensure that all areas are receiving the necessary air exchanges per hour and have necessary pressure relationships.
  - Temperature and humidity monitoring.
  - Mechanical systems, demonstrating that the systems are in service, tested, and ready for use. Systems as needed to include:
    - Medical gasses,
    - Fire alarm system,
    - Generator, including a list of the items that are supplied by emergency power
    - Sprinkler system, and
    - Electrical system-

For additional questions contact the Bureau of Ambulatory Care (BAC) at 573-751-1588 or [BAC@health.mo.gov](mailto:BAC@health.mo.gov).